

Bandon Senior High School

Coos_sch14A

Bandon SD 54

Building Type	County	
School	Coos	
Street		
550 9th St		
City	State	Zip
Bandon	OR	97411
Latitude		Longitude
43.11568		124.42044
Tracking Code		Inspection Date
RVS in 2006		8/10/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bandon Senior High School

Final RVS Score

Final Type Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
292		1975	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
60140	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Vertical Irregularity Primary



NE Plan Irregularity Primary

Bandon Senior High School

Coos_sch14B

Bandon SD 54

Building Type	County	
School	Coos	
Street		
550 9th St		
City	State	Zip
Bandon	OR	97411
Latitude		Longitude
43.11482		124.41914
Tracking Code		Inspection Date
RVS in 2006		8/10/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bandon Senior High School

Final RVS Score

Final Type Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
292		1975	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
60140	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Out of Plane Lateral-Force-Resistance Elements	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Plan Irregularity Secondary



SE Vertical Irregularity Primary



SE Plan Irregularity Primary