

Josephine County

Building Type	County	
EOC-Confidential Location - Co		
Street		
City	State	Zip
	OR	
Latitude	Longitude	
Tracking Code	Inspection Date	
RVS in 2006	7/24/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	2.4	0	0	0	6.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Josephine County Emergency Operations Center

Final RVS Score

Final Type      Final Score

W1

6.8

FEMA-154 Collapse Potential

Low (<1%)

**No  
Planview  
Available**

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None

Josephine County

Building Type	County	
EOC-Confidential Location - Co		
Street		
City	State	Zip
	OR	
Latitude	Longitude	
Tracking Code	Inspection Date	
RVS in 2006	7/24/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Josephine County Emergency Operations Center

Final RVS Score

Final Type      Final Score

RM1

2.8

FEMA-154 Collapse Potential

Low (<1%)

**No  
Planview  
Available**

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None